

Subdivision Regulations - Appendix B

Section IV

Materials Specifications and Construction Procedures

D. Drainage System Design

4. Culverts and Storm Drains

Immediately after the table for Arch Corrugated Metal Pipes, insert the following paragraph:

Dual wall high-performance polypropylene (PP) pipe, used as cross drains in traffic areas, shall conform to the standards of ASTM F2881 and AASHTO M330. High Density Polyethylene Pipe (HDPE), used in non-roadway settings, shall conform to the standards of ASTM F2306 and AASHTO M294, Type S. Installation shall be in accordance with ASTM D2321 and manufacturer's installation guidelines. Minimum cover shall be as described below. Maximum fill heights are dependent upon embedment material and compaction levels and shall be in accordance with manufacturer's recommendations.